

A Daylighted Room

Katherine Wood Varela
Nick Oelrich
Justin Traw



University of Idaho Bookstore Building Description

Location: Moscow, Idaho
North 46°
West 117 °
Elevation 2556 ft

Design: Northwest Architectural Co. in 1988.

- ❑ Concrete masonry construction with flat roof.
- ❑ Two relatively small windows on the west façade with intermittent glass block arrangement two feet above the top of the windows.
- ❑ Vestibule entrance of five standard glass pane doors with side lights and transoms.
- ❑ Four office spaces to the south, each with south-facing windows to the exterior and interior windows overlooking the main retail floor.

Space: Retail & Checkout Spaces




Building Description

Existing lights:

- ❑ Wall-mounted track lighting at window displays and Vandal Gear wall
- ❑ Suspended direct fixtures with fluorescent lamps and reflector accessories over counter spaces and at back wall
- ❑ General 2x4 fixtures, four fluorescent lamps and gridded reflector accessories, flush with ceiling tiles



Finishes & Luminance:

- ❑ Flat yellow paint on CMU walls : 24 fL
- ❑ White acoustical ceiling tiles with white trim :48 fL
- ❑ Brown commercial carpet: 24 fL
- ❑ 4x4 red-brown ceramic tile: 17 fL
- ❑ Light wood finish gondolas & shelves: 74 fL



Climate Data

Estimated daylight hours per season:



Performance Analysis


Current Electric/Daylighting Design:
FEB. 8th @ 2:20 pm

Per AGI32 Software:

- Average Illuminance (FC): 74.5
- Maximum Illuminance (FC): 158

Per Manual Light Meter:

- Average Illuminance (FC): 47.6
- Maximum Illuminance (FC): 95



Performance Analysis

Interior Electrical/Daylighting




Well distributed amount of light throughout the space:

- Most of light in the space is from the electric light fixtures and lamps
- The front of the store opposite the vestibule suffers from intense glare

Performance Analysis

Daylighting Design:
FEB. 8th @ 4:20 pm

Average Illuminance (FC): 1.32
Maximum Illuminance (FC): 16.7



Performance Analysis

Interior Daylighting



Inadequate distribution of daylight throughout the entire space

- ☐ The North side is faced with incredible amounts of gloom
- ☐ What window openings there are creates intense glare

Performance Analysis

Glare Analysis



340-200
200-240
160-200
120-160
80-120
40-80
20-40

- ☐ Glare is present on the west side of the structure where there are only two windows
- ☐ Most of the display furniture is polished and adds to the glare
- ☐ Schiller Glare (yes) with a ratio of 4.71:1

Redesign Proposal

Goals:

- ☐ Achieve an adequately daylighted space
- ☐ Keep essential wall space for merchandise display
- ☐ Keep glare to a minimum
- ☐ Limit the amount of heat gain to a space in the summer months

Methods:

- ☐ Create a series of vertical monitors
- ☐ Replace the current fixtures and lamps with LED tube lamps




Redesign Performance Analysis

Daylighting Redesign:

Average Illuminance (FC): 29.50

Maximum Illuminance (FC): 134



Redesign Performance Analysis

Interior Daylighting:



Performance Analysis

Glare Analysis:



- ☐ Glare is greatly reduced in the re-design of the bookstore
- ☐ Schlier glare (maybe) with a ratio of 2.48:1

Performance Analysis

Total exterior illumination (FC_{ext}) required to achieve recommended Daylight Factor:

Task/Space	Illumination (FC_{int})	Hours of Operation	Recommended Daylight Factor (DF)
Counters/Entry	500 Lux or 47 FC	8am-9pm	1% or 0.01
Retail Floor	750 Lux or 70 FC	8am-9pm	5% or 0.005


$$FC_{ext} = FC_{int} / DF$$

☐ For Counters/Entry: $FC_{ext} = 47 / .01 = \underline{4700 \text{ FC}}$

☐ For Retail Floor: $FC_{ext} = 70 / .005 = \underline{1400 \text{ FC}}$

Performance Analysis

Available Illumination @ 46° Latitude



- ❑ Highest illumination from 10am-2pm
- ❑ Top-lighting allows for maximized illumination throughout the year

Table B2.2.1 Cloudy Sky Illuminance Data
Equivalent sky luminance in footcandles—average overcast day

Lat.	December 21					March 21 or September 21					June 21				
	8 a.m.	9 a.m.	10 a.m.	11 a.m.	Noon	8 a.m.	9 a.m.	10 a.m.	11 a.m.	Noon	8 a.m.	9 a.m.	10 a.m.	11 a.m.	Noon
0	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000
10	400	740	1020	1210	1270	910	1300	1710	2010	2140	1270	1730	2250	2550	2550
20	360	700	960	1150	1200	880	1260	1650	1940	2070	1280	1730	2240	2540	2540
30	320	650	910	1100	1140	850	1230	1600	1870	1980	1290	1730	2220	2520	2520
36	290	620	840	1020	1070	840	1220	1590	1840	1960	1290	1730	2200	2490	2490
38	270	600	790	940	1000	830	1200	1550	1790	1940	1290	1730	2180	2460	2460
40	190	500	740	900	930	790	1140	1400	1670	1790	1290	1730	2120	2400	2400
42	170	450	690	820	860	770	1120	1410	1690	1890	1300	1690	2090	2340	2340
44	150	380	600	750	790	740	1080	1340	1640	1820	1300	1670	2050	2300	2300
46	140	360	580	730	770	710	1060	1320	1620	1800	1300	1640	2010	2260	2260
48	130	350	570	720	760	700	1040	1300	1600	1780	1300	1620	1990	2240	2240
50	120	340	560	710	750	690	1020	1280	1580	1760	1300	1600	1970	2220	2220

(Reprinted by permission from Kaytran Jeffery, IES Lighting Handbook, 10th edition, 7-6)

Performance Analysis

Daylighting Aperture Sizing:

- ❑ Existing Side Lighting – Windows and Vestibule
 - ❑ 308 SF of Existing Glazing
- ❑ New Top Lighting – Vertical Monitors
 - ❑ 1032 SF of Glazing Added

Daylight Factors Calculations:

- ❑ Total Daylight Factor for Redesign: 12%
 - ❑ $DF_{Average} = 0.2 (A_{Glazing} / A_{floor})$
 - ❑ Existing Glazing: $DF_{Average} = 0.2 (308/616) = 10\% DF$
 - ❑ New Top-Lighted Glazing: $DF_{Average} = 0.2 (1032/10,121) = 2\% DF$

Energy Savings

- By replacing the 600+ fluorescent lamps with high efficiency LED tubes the savings will be great over the lifetime of the building.



Energy Savings Calculator

Energy efficient lighting isn't just a bullet point in a mission statement, it's a lifestyle that makes your life and the world around you better. Click through the boxes below and see what a difference we make.

Energy Efficient Lamps vs. Incandescent Bulbs

Enter Your Information

Current Lamp Wattage:	110	Your Results:	
Current Cost per Lamp:	2.03	Investment Cost to Switch:	\$74392.00
Current Lamp Hours:	5000	Payback Period in Months:	35.32
With Cost \$:	13	New Lamp Replacement Cost:	\$125.00 ea.
Number of Lamps:	600	Current Electrical Cost:	\$2574.00 per month
New Replacement Lamp Wattage:	20	Electrical Cost using Energy Efficient Lamp:	\$468.00 per month
Cost of New Energy Efficient Lamp:	125	Savings Based on Switching:	\$2106.00 per month
Lifetime of New Energy Efficient Lamp:	50,000	Energy Savings Over the Life of the Energy Efficient Lamp:	\$351000.00
Hours per Day Usage:	10	Labor Cost Savings:	\$0.00
Labor Cost for Replacement:		Total Long Term Savings:	\$213198.00

High Initial Cost

Total Long Term Savings

Energy

According to the LBL Nomograph there should be a savings of 63% per year with the addition of sky lighting

An annual savings of over 15,000 due to daylighting

ENERGY SAVINGS DUE TO DAYLIGHTING

(Based on Selkowitz, S., and Gabel, M., 1984, "LBL Daylighting Nomographs," LBL report 13534, Berkeley, CA: Lawrence Berkeley Laboratory.)

Spreadsheet by Fuller Moore, Architecture Department, Miami University, Oxford OH 45056 (e-mail: ehmoores@aol.com)

	Base	Case 1
1. Enter LATitude of building location	LAT = 46.73	46.73
2. Enter the Daily Occupancy Period Code from box below (1-11)	DOPC = 5	5
3. Enter Typical Floor Width (ft):	FL = 118	118
Enter Typical Floor Length (ft):	FL = 102	102
	Typical Floor Area (ft²) = FL * FL = FA = 12036	12036
4. Enter Lighting Control Type (1 = on/off; 2 = dimming):	LCT = 1	1
5a. Enter Design Illuminance Level (30, 50, or 70 fc) =	DL = 50	50
5b. Enter window area per floor above the workplace (sf)	WAAW = 118	118
Enter typical ceiling height above floor (ft)	CH = 10	10
	Floor Perimeter (ft), FP = 440	440
	Side-Lighting Glass Area Fraction = WAAW / (CH * FP) = SLGAF = 0.026	0.026
Enter skylight or monitor glazed area (sf):	Top-Lighting Glass Area Fraction: glazed aperture area / floor area = TLGAF = 0	0.11997341
5d. Enter Side-Lighting Glass Visible Transmittance (0-0.8)	SLGVT = 0.8	0.8
Enter Top-Lighting Glass Visible Transmittance (0-0.8)	TLGVT = 0	0.8
Enter Wall Factor (0.2 to 1.0; depends on wall depth and reflectance)	WF = 0.75	0.75
6. Enter Annual Hours of Occupancy (hr)	AHO = 3100	3100
7. Enter Installed Lighting Load (watts/sf; typically 1.0 to 3.0)	ILL = 2.5	2.5
8. Electricity Cost (\$/kWh; typically 0.10 to 0.25)	EC = \$0.31	\$0.31
9. Enter No. of Floors:	NF = 1	1
Enter daylighted width (ft; 1.5 is typ. for conventional windows)	DW = 1.5	1.5
	Gross Total Building Area = NF * GAFF = GTBA = 12036	12036
10. Enter Non-Lighting Electric Load (watts/sf; 3.0 is typical for office buildings)	NLEL = 3.0	3.0
11. Peak Electric Utility Demand Rate (\$/kW-month; 2.50 is typical for office bldgs):	PDR = \$1.70	\$1.70
12. Daylighted Hours (determined from DOPC)	DH = 53.0%	93.0%
13. Total Daylighted Area (% of total; based on entered depth for skylit; 100% for top):	TDA = 47%	100%
14. Control Effectiveness (determined by LCT, side or top-lighting, and DIL):	CE = 64%	68%
15. Enter Dimming Factor (0 - 1.0; typically 0.8 for dimming systems, 1.0 for on/off)	DF = 1	1
16. Annual Energy Savings Due to Daylighting	28.2%	63.0%
17. Peak Load Savings Due to Daylighting	47.4%	100.0%
18. Non-Daylighted Lighting Energy Consumption (kWh/sf-yr)	7.75	7.75
19. Non-Daylighted Lighting Consumption Cost (\$/sf-yr)	\$2.40	\$2.40
20. Daylighting Energy Savings (kWh/sf-yr)	\$1.76	\$3.94
21. Daylighting Consumption Savings (\$/sf-yr)	\$0.55	\$1.22
22. Annual Electric Consumption Cost Savings Due to Daylighting for Building (\$'1000)	\$6.6	\$14.7
23. Non-Daylighted Peak Demand (kW)	66.198	66.198
24. Non-Daylighted Monthly Demand Charge (\$/kW-month)	0.0043	0.0043
25. Non-Daylighted Annual Demand Charge (\$/kW-yr)	\$0.051	\$0.051
26. Daylighted Peak Demand Savings (kW)	14.3	30.1
27. Daylighted Annual Demand Savings (\$/sf-yr)	0.0020	0.0043
28. Daylighted Monthly Demand Savings (\$/sf-month)	0.02415254	0.051
29. Total Annual Savings Due to Daylighting (Consumption and Demand \$/sf-yr)	\$0.570	\$1.271
30. Building Annual Savings Due to Daylighting (Consumption and Demand, per yr)	6.864	15.291
31. Enter Extra Construction Cost Due to Daylighting (\$/bldg)	DC = 100000	100000
32. Simple Payback Period (Extra Const Cost - Bldg Annual Savings)	14.5688919	6.53734069
33. Simple Return on Daylighting Investment (Bldg Annual Savings + Extra Const Cost)	7%	15%

Annual Daylighting Occupancy Lookup Table

Conclusion

Upon entering the space, we observed that it was not adequately daylighted. There is enough daylight at the entrance, but the retail floor was primarily lighted by electric fixtures.

In the original design, energy was being wasted. Because the electric lights were the main source of illuminance during the daytime, energy was being used not only for lighting but also for cooling and ventilation.

Providing the space with top lighting allows for daylight without occupying the wall space needed for merchandise. It also allows for ventilation in the summer months and solar heat gain in the winter.

Thank You

¿Questions?

“Day man, fighter of night man”