


Oblique View by Steve Schaefer, AIA

Building Loads & HPB* Goals




That rooftop mechanical unit that "No one will ever notice."


* High Performing Building

1


Two sources of loads: Skin & Internal

Skin Loads	winter	summer
Conduction	Heat Loss	Heat Gain
Infiltration	Heat Loss	Loss or Gain
Radiation	Heat Gain	Heat Gain
Internal Loads	winter	summer
People	Heat Gain	Heat Gain
Lights	Heat Gain	Heat Gain
Equipment	Heat Gain	Heat Gain


2



3



4



5

PROJECT: My Project **LOCATION: Pullman Moscow Rgnl, WA, USA**
SCHEME: Scheme 1 **LATITUDE: 48.78° North**

Opaque
 Allows you to discover and design the thermal attributes of walls and roofs.
 Available for free from UCLA. See Arch463 web site.

Material	in	R value
Inside Air Film (wall)	0.0	0.68
Gypsum Board	0.625	0.06
Studs (wood)	0.0	0.66
Joint Insulation	0.0	10.25
Air Space (wall)	1.0	0.17
Wood Siding	0.5	0.81
Outside Air Film	0.0	0.23

UWall Section Properties:

- Orientalation (Degrees from South): 0.0
- Tilt (Degrees from Horizontal): 90.0
- Surface Absorptivity (%): 26.0
- Ground Reflectance (%): 20.0

Total Thickness (ft): 8.13
Total R value: 17.25
Total U value: 0.058
Decrement Factor: 0.83
Time Lag: -3.34

View: Projection: Axonometric Cutaway
 Animate: Hourly Daily

6

Internal Heat Gains

- Lights <math>< 1.8 \text{ w/sqft}</math>
- People 225 – 710 btuh
- Equipment (Plug Loads) Varies ~2 w/sqft

See MEEB tables G.8, G.9, & G.10 for details.

7

SBEDD allows you to specify internal loads

INTERNAL LOADS: Heat Gain to Interior Space Scheme 3 : HVAC Zone : Copy 2: My First Design	Project : New Project Building Type: OFFICE BUILDING HIGHRISE City Location: Los Angeles(Westwood)
--	---

These three components of Internal Heat Loads (Lights, People, and Equipment) also add Heat Gain to interior spaces, but the Water Heater vents directly to the outdoors so does not add to Internal Loads (see Advanced Water Heater and Solar Domestic Hot Water screens). See Schedules screen for each building type.

LIGHTING: all heat gain goes to interior (hourly loads are reduced by daylight availability: see Daylighting screen)
0.75 Watts/sq. ft. Lighting Power Density Peak Hour: Heat Gain is 3.412 BTU/h/Watt (Code Standard Value=0.75)

OCCUPANTS: all Sensible Heat goes to the interior. If there is an air conditioner all Latent Heat also goes to the interior
20.00 Number of OCCUPANTS on Peak Hour: (Code Standard is 100.00 sq. ft./person) see Schedules screen
250.00 BTU Sensible Heat Gain per Occupant on Peak Hour: (Code Standard is 250.00 BTU/h/person)
200.00 BTU Latent Heat Load on Air conditioner per Occupant on Peak Hour: (Code Standard is 200.00 BTU/h/person)

EQUIPMENT and PLUG LOADS: all heat gain from these electrical and gas loads goes to the interior (input changes on Advanced Equipment and Plug Loads screen, see also Advanced Schedules screen)
0.00 BTU/h/sq. ft. Gas Equipment Peak Hour (NACH Standard is 0.00 BTU/h/sq/ft)
0.00 Watts/sq. ft. Refrigeration Equipment Peak Hour: Heat Gain at 3.412 BTU/h/Watt (NACH Standard is 0.00 Watts/sq. ft.)
1.50 Watts/sq. ft. Receptacle Electrical Plug Load Peak Hour: Heat Gain at 3.412 BTU/h/Watt (NACH Standard=0.00 Watts/sq. ft.)
0.00 Watts Exhaust Hood less than 5000 CFM Peak Hour total Nameplate Wattage (no Code Standard so is initially set to 0.0 watts)
0.00 Watts Exhaust Hood greater than 5000 CFM Peak Hour total Nameplate Wattage (no Code Standard so is initially set to 0.0 watts)
0.00 Watts Elevators total Peak Hour (no Code Standard so is initially set to 0.0 watts)

8

Hopkins Architects

What makes a building “green”?

Active Systems


Passive elements

Form and orientation


Energy saving potential

Cost

9



10




11

Table C1.6.1 Energy Conservation Strategies


Characteristic Balance Point Temperature Chart	Strategies											
	Interior temperature setting		Internal heat generation		Solar heat gain		Rate of heat gain or loss through envelope		Rate of heat gain or loss by ventilation		Thermal storage	
	increase	decrease	increase	decrease	increase	decrease	increase	decrease	increase	decrease	store heat	store cool
heating always required		X	X		X		X		X			
heating		X	X		X		X		X			X
cooling-outside warmer than inside	X			X		X		X		X		X
cooling-outside cooler than inside	X			X		X	X		X			X
outside warmer than inside	X			X		X		X		X		
cooling always required	X			X		X	X		X			X

Adapted, by permission, from Brown, Sun, Wind, and Light, 61, copyright © 1985, John Wiley & Sons, Inc.

12



13



14

Use SBED for initial building design...

Window Layout
Scheme 3 : HVAC Zone : Copy 2: My First Design

Project : New Project
Building Type: OFFICE BUILDING HIGHRISE
City Location: Los Angeles (Westwood)

Front View
(Facing South)

4'x 4' grid

15

Specify internal loads

INTERNAL LOADS: Heat Gain to Interior Spaces
Scheme 3 : HVAC Zone : Copy 2: My First Design

Project : New Project
 Building Type: OFFICE BUILDING HIGHRISE
 City Location: Los Angeles(Westwood)

These three components of Internal Heat Loads (Lights, People, and Equipment) also add Heat Gain to Interior spaces, but the Water Heater vents directly to the outdoors so does not add to Internal Loads (see Advanced Water Heater and Solar Domestic Hot Water screens). See Schedules screen for each building type.

LIGHTING: all heat gain goes to interior (hourly loads are reduced by daylight availability; see Daylighting screen)

0.75 Watts/sq Ft. Lighting Power Density Peak Hour: Heat Gain is 3.412 BTU/h/Watt (Code Standard Value=0.75)

OCCUPANTS: all Sensible Heat goes to the interior. If there is an air conditioner all Latent Heat also goes to the interior

20.00 Number of OCCUPANTS on Peak Hour: (Code Standard is 100.00 so Ft./person) see Schedules screen
 250.00 BTU Sensible Heat Gain per Occupant on Peak Hour: (Code Standard is 250.00 BTU/h/person)
 200.00 BTU Latent Heat Load on Air conditioner per Occupant on Peak Hour: (Code Standard is 200.00 BTU/h/person)

EQUIPMENT and PLUG LOADS: all heat gain from these electrical and gas loads goes to the interior (Input changes on Advanced Equipment and Plug Loads screen, see also Advanced Schedules screen)

0.00 BTU/h/sq Ft. Gas Equipment Peak Hour (NACH Standard is 0.00 BTU/h/sq Ft.)
 0.00 Watts/sq Ft. Refrigeration Equipment Peak Hour: Heat Gain at 3.412 BTU/h/Watt (NACH Standard is 0.00 Watts/sq Ft.)
 1.50 Watts/sq Ft. Acceptable Electrical Plug Load Peak Hour: Heat Gain at 3.412 BTU/h/Watt (NACH Standard=0.00 Watts/sq Ft.)
 0.00 Watts Exhaust Hood less than 5000 CFM Peak Hour total Nameplate Wattage (no Code Standard so is initially set to 0.0 watts)
 0.00 Watts Exhaust Hood greater than 5000 CFM Peak Hour total Nameplate Wattage (no Code Standard so is initially set to 0.0 watts)
 0.00 Watts Elevators total Peak Hour (no Code Standard so is initially set to 0.0 watts)

16

Specify windows and their shading devices

WINDOW/SUNSHADE/DOOR DESIGN
Scheme 3 : HVAC Zone : Copy 2: My First Design

Project : New Project
 Building Type: OFFICE BUILDING HIGHRISE
 City Location: Los Angeles(Westwood)

LOCATION	DIMENSIONS GLAZING				ORIENTATION	Drape	OVERHANG	LEFT FIN	RIGHT FIN					
	Quantity	Width	Height	U factor Trans. SHGC Fading** Tilt						R-value	** Depth	Offset	Depth	Offset
South Window	17	6.00	8.83	0.300	0.52	0.25	-45.00	90.00	0.00	3.00	0.00	0.00	0.00	0.00
South Door	2	3.00	6.87	0.700	0.89	0.50	-45.00	90.00	0.00	5.00	0.00	0.00	0.00	0.00
North Window	7	6.00	8.83	0.300	0.52	0.25	135.00	90.00	0.00	3.00	0.00	0.00	3.00	0.00
North Door	2	3.00	6.87	0.700	0.89	0.50	135.00	90.00	0.00	5.00	0.00	0.00	0.00	0.00
Add Type														

To add a new window or door, click on Add Type and choose one. To delete a window or door, change its Quantity to 0.
 To change a window type, first add a brand new one and then delete the old one (change its Quantity to 0).
 Operable Insulation have an R-value of 1 for thin fabric or 3 to 5 for thick fabric tightly sealed, closes at night in cold weather.
 *Fading direction starts clockwise from South (i.e. South Facing = 45 up to 90, West Facing = 45 up to 135)
 ** This Column adds Operable Sunshades (as defined on the Basic Operable Shading Menu). To add to any window click the icon and a Check will appear. To remove from any window, click this check.

17

Specify occupancy schedule


Schedules
Scheme 3 : HVAC Zone : Copy 2: My First Design

Project : New Project
 Building Type: OFFICE BUILDING HIGHRISE
 City Location: Los Angeles(Westwood)


Work Day Schedule: Occupancy Units: Percent Revised By: [No]

Select the Schedule description from the above drop-down list of the available WorkDay options (as given on AECM Appendix E.46).
 These schedules are listed for California Title 24 compliance buildings, but can be used by simply entered values on the Units input box.
 Some Schedules are NOT currently implemented: HVAC As a whole percent, Infiltration percent, Elevators, Escalators, or Exhaust Hoods.
 (You can select one or more bars and drag them vertically to change their values.)


18




19




20



21



22



23

THE COMMON DEFINITION OF BUILDING EUI IS:

$$\frac{\text{Annual Building Energy Use (kBtus or MJ)}}{\text{Building Area (ft}^2 \text{ or m}^2\text{)}} = \text{EUI}$$

24

Convert Fuel Use to Source Energy Worksheet

Fuel	Annual fuel use	Fuel units	Multiplier	Annual energy use in source kBtu
Electricity		kWh	x 10.3	=
Electricity		MWh	x 10300	=
Natural gas		MCF	x 1000	=
Natural gas		CCF	x 100	=
Natural gas		CF	x 1	=
Natural gas		MMBtu	x 1000	=
Natural gas		therms	x 100	=
Fuel oil #2		gallons	x 139	=
Kerosene		gallons	x 135	=
Propane		gallons	x 91	=
Coal		tons	x 22000	=
District steam		lbs	x 1,6124	=
District steam		kibs	x 1612.4	=
District steam		kBtu	x 1.39	=
District steam		MMBtu	x 1390	=
District hot water			x	=
District hot water			x	=
District hot water			x	=
District chiller water		ton-hrs	x 12	=
District chiller water		kBtu	x 1	=
District chiller water		MMBtu	x 1000	=
Total annual source energy use (kBtu)				=

1 Calculate using your fuel uses and appropriate multipliers. Then sum column for total.
 2 MMBtu = 1,000,000 Btu.
 3 The coal multiplier could be as low as 16000 and as high as 26000 kBtu/ton. Check with supplier.

25

Key Terms: "Scopes" 1, 2, and 3

Combustion

- Scope 1:** Direct GHG emissions - Direct GHG emissions occur from sources that are owned or controlled by the company, for example, emissions from combustion in owned or controlled boilers, furnaces, vehicles, etc.

Electricity


- Scope 2:** Electricity indirect GHG emissions - Scope 2 accounts for GHG emissions from the generation of purchased electricity consumed by the company. Purchased electricity is defined as electricity that is purchased or otherwise brought into the organizational boundary of the company.

Off-Site

- Scope 3:** Other indirect GHG emissions Scope 3 is an optional reporting category that allows for the treatment of all other indirect emissions. Scope 3 emissions are a consequence of the activities of the company, but occur from sources not owned or controlled by the company.

The Greenhouse Gas Protocol, A Corporate Accounting and Reporting Standard,
World Business Council for Sustainable Development and World Resources Institute, 2004.



26




27



28




29



2009 ENERGY USE										
	Electricity kWh	Electricity Cost	Natural Gas Therms	Natural Gas Cost	Geothermal Gallons*	Geothermal Cost	2009 Heating Degree Days	2009 Cooling Degree Days	2002-08 Avg. HDD	2002-08 Avg. CDD
Jan	393,848	\$17,828	521	\$542	2,184	\$8,064	1037	0	1007	0
Feb	363,231	\$17,997	387	\$408	1,792	\$6,820	779	0	812	0
Mar	406,402	\$20,129	418	\$443	1,427	\$5,323	716	0	624	0
Apr	419,814	\$20,117	436	\$472	936	\$3,659	430	7	426	1
May	447,331	\$21,311	498	\$539	833	\$3,260	187	87	199	50
Jun	460,743	\$29,114	518	\$560	1,054	\$4,120	24	114	55	175
Jul	507,434	\$31,661	615	\$663	863	\$3,373	0	428	0	446
Aug	459,462	\$28,850	561	\$597	223	\$889	14	338	5	323
Sep	433,340	\$24,346	554	\$584	169	\$673	40	214	88	96
Oct	389,011	\$21,998	475	\$421	402	\$1,941	505	0	370	10
Nov	361,645	\$20,316	966	\$901	910	\$3,523	701	0	724	0
Dec	396,944	\$21,455	2,952	\$2,320	1,398	\$5,174	1,179	0	958	0
Total	5,042,205	\$275,142	8,941	\$8,380	12,281	\$46,619	5,612	1,188		

*in thousand

30



ENERGY AT A GLANCE

Energy Use Intensity (Site) 64 kBtu/ft²
Natural Gas 3 kBtu/ft²
Electricity 48 kBtu/ft²
Geothermal 13 kBtu/ft²

Annual Source Energy 176 kBtu/ft²

Annual Energy Cost Index (ECI)
\$0.93/ft²·yr

Peak Load 1450 kW (2009)

Base Load 935 kW (2009)

Load Factor 47.6% (2009)


ENERGY STAR Rating 84 (2009),
85 (2008), 85 (2007), 83 (2006),
75 (2005), 76 (2004)

31

John Hope Gateway
RBGE
Cullinan Studio



32




33




34



35



36




37

Energy Performance Certificate for buildings other than dwellings

Building Energy Performance		Scotland
Calculated asset rating using IES eVEn v6.0.6 (ApacheSim)	Building type: Libraries/museums/galleries	Current rating: Excellent
	Carbon Neutral	
	A (0 to 15)	
	B (16 to 30)	B+
	C (31 to 45)	
	D (46 to 60)	
	E (61 to 80)	
	F (81 to 100)	
G (100+)	Very Poor	
Carbon Dioxide Emissions The number refers to the calculated carbon dioxide emissions in terms of kg per m ² of floor area per year.	16	
Approximate current energy use per m ² of floor area:	135 kWh/m ²	42 kbtu/sqft
Main heating fuel: Biomass	Building Services: Heating with Nat. Vent.	
Renewable energy source:	Electricity: Grid supplied	
Carbon Dioxide is a greenhouse gas which contributes to climate change. Less Carbon Dioxide emissions from buildings helps the environment.		
Benchmarks		
A building of this type built to building regulations standards current at the date of issue of this certificate would have a rating: 33		
Where the accompanying recommendations for the cost effective improvement of energy performance are applied, this building would have a rating: 0		
Recommendations for the cost-effective improvement (lower cost measures) of the energy performance:		

38



39

Public building CO2 footprints revealed (8 pictures) guardian.co.uk

6 / 8

Thumbnail view


Environment
Energy efficiency
Carbon emissions
Green building

UK news

More on this story


Nearly half of FTSE-250 companies keep their carbon footprints hidden

Halls of shame: UK's biggest CO2 offenders



6 / 8
City Hall, London
Energy efficiency rating: E
Annual CO2 emissions: 2,255 tonnes of carbon
New buildings also faced scrutiny, raising questions about the validity of sustainability claims made by architects and developers. London's City Hall, built in 2002, was described by its architect Foster & Partners as a 'virtually non-polluting public building' yet has scored an E
Photograph: David Levene

40




Display Energy Certificate
How efficiently is this building being used?

Energy efficiency: E

Annual CO2 emissions: 2,255 tonnes of carbon

Energy efficiency scale: A (0-25), B (26-50), C (51-75), D (76-100), E (101-150), F (151-200), G (over 200)

41



PV Array (usually building mounted)

Control / Protection

Inverter


Control / Protection

Grid


Two-way metering

Load


42



43



44



45



100 90 80 70 60 50 40 30 20 10 0

E 101-125

F 126-150

G Over 150

Less energy efficient

Previous Operational Ratings

This tells you how efficiently energy has been used in this building over the last three accounting periods

Period	Rating
Apr 2007	108
Apr 2006	133
Mar 2005	153

Technical information

This tells you technical information about how energy is used in this building. Consumption data based on actual readings.

Main heating fuel: Gas
 Building Environment: Air Conditioned
 Total useful floor area (m²): 2927
 Asset Rating: G2

	Heating	Electrical
Annual Energy Use (kWh/m ² /year)	126	129
Typical Energy Use (kWh/m ² /year)	120	95
Energy from renewables	0%	20%

Administrative information

This is a Display Energy Certificate as defined in S2007:991 as amended.

Assessment Software: CR14
 Property Reference: 891123779612
 Assessor Name: John Smith
 Assessor Number: AGC12345
 Accreditation Scheme: AGC Accreditation Ltd
 Employer/Trading Name: Energy Watch Ltd
 Employer/Trading Address: Alpha House, New Way, Birmingham, B2 1AA
 Issue Date: 12 May 2007
 Nominated Date: 01 Apr 2007
 Valid Until: 31 Mar 2008

Related Party Disclosure: Energy Watch are contracted as energy managers. Recommendations for improving the energy efficiency of the building are contained in Report Reference Number 1234-1234-1234-1234

Note: Buildings don't use energy, people do. It's useful to measure in kWh/occupant/year too.
