

Case Study #1: A Daylighted Room


Johnson Chou

Thomas Corr

Zhimin Zhu



Case Study




Moscow, ID



Commons at U of I



4th Floor of the Commons



Panorama Room




Case Study



- Adequately lighting
- Well design daylighting for potential saving energy
- Daylight can be improved with change to top lighting




Case Study




- Room Description
 - Located at Center of University of Idaho
 - In Commons
 - 4th Floor
 - Facing East
 - Wall
 - 10 ft. towards east
 - 29 ft. towards the west
 - 2 Exterior wall
 - North
 - 2 Large window
 - East
 - Large window wall
 - Have a exterior balcony
 - Large Ceiling
 - Incoming skylight
 - Daylight monitor

Climate Data





Ave. 3200 FC / yr




Avg. 50% Cloud coverage / yr

Performance Analysis


- The room receives adequate daylighting but has the potential to be improved through the building's top ceiling fixture and daylight monitors. There is a 29 foot wall including the daylight monitor that is design at the wrong height and angle. This creates an issue of daylight does not enter the lower half of the room.



Performance Analysis




Daylighting Plan



Illumination Footprint


Performance Analysis

- Electrical Lighting Scheme
- Fluorescent lighting
 - 8 bulb/fixture
 - 40 watts/bulb
 - 1080 hour/yr.
 - 1,382.4 kw/yr.
 - \$8.97 / blub
 - 22,075 hours / bulb
 - \$154.24 / yr for electric lighting




Light Fixtures Plan

Glare Analysis



Overall Image		Individual Pixel	
Weighted Ave Pixel Intensity	87.66	Individual Pixel Value	130
Total Number of Pixels	76600	Corresponding Luminance	291.89 footcandle
Background Bell Curve		Spike	
Low End Pixel Value	5	Low End Pixel Value	125
High End Pixel Value	65	High End Pixel Value	140
Background Median Value	25	Spike Median Value	132




Panorama Room Before Redesign

Redesign Room

The Ultimate Goal:

To improve daylight distribution throughout the room during properly work hours.




Original Panorama Room



Redesigned Panorama Room


Redesign Room




By changing the height of the daylight monitor, we increase the rate of daylight staying inside the room.


Redesign Room

- By change the angles and location of the clerestory window we redirect the daylight into the room creating a much brighter shape.



- To ensure that no direct dawn sun light goes straight into the room, we change the west side window to be controllable to be dimmed.





Energy

ENERGY SAVINGS DUE TO DAYLIGHTING	
Bentley Software, Inc. and Global V. 10K. "SCL Daylighting Homogenizer" LRL report 1/24/14 Berkeley, CA Lawrence Berkeley Laboratory Spreadsheet by Fisher Hesse, Architecture Department, Miami University, Oxford OH 45308 (email: hesse@umiami.edu)	
Enter LA Trade of building location	LAT = 46.2
Enter the Daylighting Percent Coefficient from below (0-100)	DOPC = 7
1 = 10-10h, 20-10h, 30-10h, 40-10h, 50-10h, 60-10h, 70-10h, 80-10h, 90-10h, 100-10h	
Enter Typical Floor Width (ft)	F1 = 32
Enter Typical Floor Length (ft)	F2 = 32
Typical Floor Area (ft ²) = F1 * F2 = 1024	
Enter Lighting Control Type (1 = manual 2 = dimming)	LCT = 2
Enter Design Illuminance Level (30, 35, or 70 fc)	DL = 30
Enter window area per floor above the workplane (sq)	WA = 124.4
Enter typical window height above floor (ft)	CH = 10
Floor Penetration (FP) = 1.00	
Side Lighting Glass Area Factor = Window * CH * FP * 16 / LGF = 0.115	
Enter daylight or monitor glass area (sq)	AG = 0
Enter Side Lighting Glass Visible Transmittance (0-1)	SLGT = 0
Enter Top Lighting Glass Visible Transmittance (0-1)	TLGT = 0
Enter Wall Factor (0-1.0, depends on wall depth and reflectance)	WF = 0
Enter Annual Hours of Occupancy (hr)	AHO = 1000
Enter installed lighting load (watts/m ² typically 1 thru 10)	ILL = 2.5
Electric Cost (\$/kWh, typically 0.10 to 0.20)	EC = \$0.13
Electricity Cost (\$/kWh, typically 0.10 to 0.20)	EC = \$0.13
Enter No. of floors	NF = 1
Enter daylighted width (ft, 15 to 16 for conventional windows)	DW = 15
Enter "Total Building Area" = LGF * AGF = 1024	
Enter Non Lighting Electric Load (watts/m ² , 3.0 is typical for office building)	NLE = 3.0
Peak Electric Load Demand from Building (kW, 2.0 is typical for office building)	PEL = \$0.56
Daylighted Floor Area (square meters) (0-1)	DA = 0.06
Total daylighted area (1.0 m ² = 10.764 sq ft) (0-100% of total floor area)	TDA = 100%
Control Efficiency (determined by LCT, side or top lighting, and DCL)	CE = 0.18
Enter Window Factor (0-1.0, typically 0.0 for dimming systems, 1.0 for constant ON)	WF = 0.06
Annual Energy Savings Due to Daylighting	\$0.76
Peak Load Savings Due to Daylighting	\$0.76
Non-Daylighted Lighting Consumption (kWh/yr)	\$2.70
Daylighting Energy Savings (kWh/yr)	\$0.36
Daylighting Consumption Savings (kWh/yr)	\$0.42
Annual Electric Consumption Cost Savings Due to Daylighting for Building (10000)	\$0.42
Non-Daylighted Peak Demand (kW)	0.002
Non-Daylighted Annual Demand Charge (\$/month)	\$0.075
Daylighted Peak Demand Savings (kW)	0.002
Daylighted Annual Demand Charge Savings (\$/month)	\$0.002
Total Annual Savings Due to Daylighting Consumption and Demand (kWh/yr)	\$0.807
Building Annual Savings Due to Daylighting Consumption and Demand, per sq	\$0.807
Enter Extra Demand Cost Due to Daylighting (kWh/yr)	0
Enter Extra Demand Cost Due to Daylighting (kWh/yr)	0
Simple Return on Daylighting Investment (Bldg Annual Savings + Extra Demand Cost)	200.001
Simple Return on Daylighting Investment (Bldg Annual Savings + Extra Demand Cost)	0%

Case w/ no daylight

ENERGY SAVINGS DUE TO DAYLIGHTING	
Bentley Software, Inc. and Global V. 10K. "SCL Daylighting Homogenizer" LRL report 1/24/14 Berkeley, CA Lawrence Berkeley Laboratory Spreadsheet by Fisher Hesse, Architecture Department, Miami University, Oxford OH 45308 (email: hesse@umiami.edu)	
Enter LA Trade of building location	LAT = 46.2
Enter the Daylighting Percent Coefficient from below (0-100)	DOPC = 7
1 = 10-10h, 20-10h, 30-10h, 40-10h, 50-10h, 60-10h, 70-10h, 80-10h, 90-10h, 100-10h	
Enter Typical Floor Width (ft)	F1 = 32
Enter Typical Floor Length (ft)	F2 = 32
Typical Floor Area (ft ²) = F1 * F2 = 1024	
Enter Lighting Control Type (1 = manual 2 = dimming)	LCT = 2
Enter Design Illuminance Level (30, 35, or 70 fc)	DL = 30
Enter window area per floor above the workplane (sq)	WA = 124.4
Enter typical window height above floor (ft)	CH = 10
Floor Penetration (FP) = 1.00	
Side Lighting Glass Area Factor = Window * CH * FP * 16 / LGF = 0.115	
Enter daylight or monitor glass area (sq)	AG = 100
Enter Side Lighting Glass Visible Transmittance (0-1)	SLGT = 0.15
Enter Top Lighting Glass Visible Transmittance (0-1)	TLGT = 0.15
Enter Wall Factor (0-1.0, depends on wall depth and reflectance)	WF = 0.15
Enter Annual Hours of Occupancy (hr)	AHO = 1000
Enter installed lighting load (watts/m ² typically 1 thru 10)	ILL = 2.5
Electric Cost (\$/kWh, typically 0.10 to 0.20)	EC = \$0.13
Electricity Cost (\$/kWh, typically 0.10 to 0.20)	EC = \$0.13
Enter No. of floors	NF = 1
Enter daylighted width (ft, 15 to 16 for conventional windows)	DW = 15
Enter "Total Building Area" = LGF * AGF = 1024	
Enter Non Lighting Electric Load (watts/m ² , 3.0 is typical for office building)	NLE = 3.0
Peak Electric Load Demand from Building (kW, 2.0 is typical for office building)	PEL = \$1.43
Daylighted Floor Area (square meters) (0-1)	DA = 0.06
Total daylighted area (1.0 m ² = 10.764 sq ft) (0-100% of total floor area)	TDA = 100%
Control Efficiency (determined by LCT, side or top lighting, and DCL)	CE = 0.18
Enter Window Factor (0-1.0, typically 0.0 for dimming systems, 1.0 for constant ON)	WF = 0.06
Annual Energy Savings Due to Daylighting	\$7.65
Peak Load Savings Due to Daylighting	\$7.65
Non-Daylighted Lighting Consumption (kWh/yr)	\$2.70
Daylighting Energy Savings (kWh/yr)	\$1.19
Daylighting Consumption Savings (kWh/yr)	\$0.47
Annual Electric Consumption Cost Savings Due to Daylighting for Building (10000)	\$0.55
Non-Daylighted Peak Demand (kW)	0.002
Non-Daylighted Annual Demand Charge (\$/month)	\$0.075
Daylighted Peak Demand Savings (kW)	0.002
Daylighted Annual Demand Charge Savings (\$/month)	\$0.002
Total Annual Savings Due to Daylighting Consumption and Demand (kWh/yr)	\$1.01
Building Annual Savings Due to Daylighting Consumption and Demand, per sq	\$1.01
Enter Extra Demand Cost Due to Daylighting (kWh/yr)	0
Enter Extra Demand Cost Due to Daylighting (kWh/yr)	0
Simple Return on Daylighting Investment (Bldg Annual Savings + Extra Demand Cost)	184.466
Simple Return on Daylighting Investment (Bldg Annual Savings + Extra Demand Cost)	2%

Simple Return on Daylighting Investment (Bldg Annual Savings + Extra Const Cos 1% 2%

Original and Redesigned Room

Conclusion

- Overall, the Panorama room was already very well lit
- We made little tweaks to the room that improved the overall energy use and ability of daylight to get into the room
 - Lower clerestory window height
 - Change the angle in which daylight comes into the room

The End

• Thank you for Listening