

# IRIC BUILDING

TEAM **2**

PROPOSED NBBJ BUILDING



**Location: Moscow, Idaho**

**Actual Architects: NBBJ**

**Occupancy: 300**

**Client: University of Idaho**


**Square Footage: 70, 500 sqft**

**Type: Integrated Lab**

**3 Floors**

|  |              |
|--|--------------|
| • <b>Goals</b> .....   | <b>2</b>     |
| • <b>Trees that Influenced the Project</b> .....                   | <b>3-4</b>   |
| • <b>Site Context</b> .....  | <b>5</b>     |
| • <b>Site</b> .....  | <b>6</b>     |
| • <b>Floor Plans</b> .....   | <b>7</b>     |
| • <b>Sections</b> .....  | <b>8</b>     |
| • <b>Perspectives</b> .....  | <b>9-12</b>  |
| • <b>Structure - Calculations, Diagrams</b> .....                  | <b>12-14</b> |
| • <b>Chaswick Park - Case Study</b> .....                          | <b>14</b>    |
| • <b>BIPV's - Material Case Study, Snow Load, Energy</b> .....     | <b>15-17</b> |
| • <b>Light - Types used, Calculations</b> .....                    | <b>18-19</b> |
| • <b>Appliance Load</b> .....                                      | <b>20</b>    |
| • <b>Envelope - Detailed wall Section, Wall values</b> .....       | <b>21-22</b> |
| • <b>Heating Load - Calculations</b> .....                         | <b>22-24</b> |
| • <b>Cooling Load - Calculations</b> .....                         | <b>25-27</b> |
| • <b>Water Management - Diagrams, Toilets/Site Calculations</b> .. | <b>28-30</b> |
| • <b>Conclusion</b> .....  | <b>31</b>    |

- **Re-Design in Idaho Forest Species**
  - Structure
  - Envelope
  - Express the wood in accordance to its properties and strengths
  - Protect the wood from the natural elements
  - Use the wood in its most natural state
    - Straight from the saw mill
- **Responsible Design**
  - Structure
  - Envelope
  - Daylighting
  - Water
  - Systems
  - On-site power
- **Educational**
  - Exposed structure
  - Exposed systems
  - Exposed water
  - Tree species







Douglas Fir  
Glue-Laminated Timber



Ponderosa Pine  
2x6 Framing



Mountain Hemlock  
Interior paneling





Western Hemlock  
Flooring




Western Red Cedar  
Exterior & Interior Paneling



Western Larch  
Window molding



# CONTEXT



College of  
Natural  
Resources

Site


Ag Science

Mines

Ren  
frew  
Hall

Library  
Idaho  
Commons





Mall

West Entrance

Ramp

IRIC Building

East Entrance

N







Southwest





Atrium






# PERSPECTIVE

TEAM 2


Entrance






# PERSPECTIVE


TEAM 2









2' x 9" Beam




22.5" x 9" Beam




16.5" x 5.5" Beam




15" x 5.5" Beam



9" x 3.5" Beam




2" x 6" Joist




9" x 9" Column

## Heavy Timber/Post and Beam Glulam Structure

Tree Species: Douglas Fir



Footing to Column Connector



Angled Column Connector

- 1** Span : 40'  
40'/20 = **2'**

2'(24") x .33(depth) = **7.92"**  
(1) 2x4 + (1) 2x 6 = 9"

1 row of 16 2x4's  
@1.5"x3.5"

1 row of 16 2x6's  
@1.5"x5.5"

---

**2** Span : 37'  
37'/20 = **1.85'**

1.85'(22") x .33(depth) = **7.26"**  
1 - 2x4 + 1 - 2x 6 = 9"

1 row of 15 2x4's  
@1.5"x3.5"

1 row of 15 2x6's  
@1.5"x5.5"

---

**3** Span : 14'  
14'/20 = **.7'**

.7'(9") x .33(depth) = **2.97"**

6 2x4's  
@1.5"x3.5"

---

**4** Span : 26'  
26'/20 = **1.3'**

1.3'(16") x .33(depth) = **5.28"**

11 2x6's  
@1.5"x5.5"

---

**5** Span : 22'  
22'/20 = **1.1'**

1.1'(14") x .33(depth) = **4.62"**

10 2x6's  
@1.5"x5.5"

---

**6** Span : 7'6"

Can span up to 8' for 2'x6'

Joists are spaced at 4'

---

**7** 8" x 8" Wood Columns  
can support up to 1000  
sq. ft. of floor area.

Area: 40' x 22' = 880sqft  
(1)2x4 + (1)2x 6 = 9"

1 row of 6 2x4's  
@1.5"x3.5"

1 row of 6 2x6's  
@1.5"x5.5"

**12** 2x6 Wood Framing


**13** 230 - 14" TGI's 16" o.c.




| Depth | TJI® | 40 PSF Live Load / 10 PSF Dead Load |          |                       |                        | 40 PSF Live Load / 20 PSF Dead Load |                       |                       |                        |
|-------|------|-------------------------------------|----------|-----------------------|------------------------|-------------------------------------|-----------------------|-----------------------|------------------------|
|       |      | 12" o.c.                            | 16" o.c. | 19.2" o.c.            | 24" o.c.               | 12" o.c.                            | 16" o.c.              | 19.2" o.c.            | 24" o.c.               |
| 9½"   | 110  | 16'-11"                             | 15'-6"   | 14'-7"                | 13'-7"                 | 16'-11"                             | 15'-6"                | 14'-3"                | 12'-9"                 |
|       | 210  | 17'-9"                              | 16'-3"   | 15'-4"                | 14'-3"                 | 17'-9"                              | 16'-3"                | 15'-4"                | 14'-0"                 |
|       | 230  | 18'-3"                              | 16'-8"   | 15'-9"                | 14'-8"                 | 18'-3"                              | 16'-8"                | 15'-9"                | 14'-8"                 |
| 11½"  | 110  | 20'-2"                              | 18'-5"   | 17'-4"                | 15'-9" <sup>(1)</sup>  | 20'-2"                              | 17'-8"                | 16'-1" <sup>(1)</sup> | 14'-4" <sup>(1)</sup>  |
|       | 210  | 21'-1"                              | 19'-3"   | 18'-2"                | 16'-11"                | 21'-1"                              | 19'-3"                | 17'-8"                | 15'-9" <sup>(1)</sup>  |
|       | 230  | 21'-8"                              | 19'-10"  | 18'-8"                | 17'-5"                 | 21'-8"                              | 19'-10"               | 18'-7"                | 16'-7" <sup>(1)</sup>  |
|       | 360  | 22'-11"                             | 20'-11"  | 19'-8"                | 18'-4"                 | 22'-11"                             | 20'-11"               | 19'-8"                | 17'-10" <sup>(1)</sup> |
|       | 560  | 26'-1"                              | 23'-8"   | 22'-4"                | 20'-9"                 | 26'-1"                              | 23'-8"                | 22'-4"                | 20'-9" <sup>(1)</sup>  |
| 14"   | 110  | 22'-10"                             | 20'-11"  | 19'-2"                | 17'-2" <sup>(1)</sup>  | 22'-2"                              | 19'-2"                | 17'-6" <sup>(1)</sup> | 15'-0" <sup>(1)</sup>  |
|       | 210  | 23'-11"                             | 21'-10"  | 20'-8"                | 18'-10" <sup>(1)</sup> | 23'-11"                             | 21'-1"                | 19'-2" <sup>(1)</sup> | 16'-7" <sup>(1)</sup>  |
|       | 230  | 24'-8"                              | 22'-6"   | 21'-2"                | 19'-9" <sup>(1)</sup>  | 24'-8"                              | 22'-2"                | 20'-3" <sup>(1)</sup> | 17'-6" <sup>(1)</sup>  |
|       | 360  | 26'-0"                              | 23'-8"   | 22'-4"                | 20'-9" <sup>(1)</sup>  | 26'-0"                              | 23'-8"                | 22'-4" <sup>(1)</sup> | 17'-10" <sup>(1)</sup> |
|       | 560  | 29'-6"                              | 26'-10"  | 25'-4"                | 23'-6"                 | 29'-6"                              | 26'-10"               | 25'-4" <sup>(1)</sup> | 20'-11" <sup>(1)</sup> |
| 16"   | 210  | 26'-6"                              | 24'-3"   | 22'-6" <sup>(1)</sup> | 19'-11" <sup>(1)</sup> | 26'-0"                              | 22'-6" <sup>(1)</sup> | 20'-7" <sup>(1)</sup> | 16'-7" <sup>(1)</sup>  |
|       | 230  | 27'-3"                              | 24'-10"  | 23'-6"                | 21'-1" <sup>(1)</sup>  | 27'-3"                              | 23'-9"                | 21'-8" <sup>(1)</sup> | 17'-6" <sup>(1)</sup>  |
|       | 360  | 28'-9"                              | 26'-3"   | 24'-8" <sup>(1)</sup> | 21'-5" <sup>(1)</sup>  | 28'-9"                              | 26'-3" <sup>(1)</sup> | 22'-4" <sup>(1)</sup> | 17'-10" <sup>(1)</sup> |
|       | 560  | 32'-8"                              | 29'-8"   | 28'-0"                | 25'-2" <sup>(1)</sup>  | 32'-8"                              | 29'-8"                | 26'-3" <sup>(1)</sup> | 20'-11" <sup>(1)</sup> |




Plan



Isometric




Section



14 40' Concrete Pile


15 Tension Cables

15





# CHISWICK PARK (CASE STUDY) TEAM 2



Location: London, England  
Type: Mixed Use - Offices  
12 building in master plan  
Richard Rogers Partnership  
Client: Stanhope plc  
Main Contractor: Bovis Lend Lease  
Structural Engineer: Ove Arup & Partners

I studied this building because of the large shading structure the building provides, and the tension cable details.





## Building Integrated Photovoltaics (BIPV)

Provides a designer with completely new possibilities. The wide variety of elegant forms, colors, and optical structures of cells, glass, and profiles. It enables many creative and modern approaches to design. They can be incorporated vertically, horizontally, and at an angle. The panels can be customized to desired dimensions. The amount of cells and the positioning can also be customized to the needs of the designer. Used for transparency, light control, and shading.



I studied and chose this material because it generates clean energy, it can be used for shading, and it can shelter people from the elements.





## Building Integrated Photovoltaics (BIPV)

Snow Load: 30psf(1.4kN/m-squared) An example from a company that specializes in PV's. [www.sunforson.com](http://www.sunforson.com)

Calculating snow load in psf  
Depth of snow in inches - convert inches into feet.  
Multiply the depth by the weight

Average snow weight in Idaho: 10-20 psf(pounds per square foot)

According to the University of Idaho, Moscow receives an average of 49", of snow, each year. Moscow receives the most in January with 16"

The average amount of snow to fall, in a single period, in January is 4"

### Calculations

Average snow weight in Idaho: 10-20 psf(pounds per square foot)  
If it snowed 1'6" or 18" = 1.5'  
 $1.5' \times 20 \text{ psf} = 30 \text{ psf}$

The Building Integrated Photovoltaics could hold an estimated 1'6" (18") of Idaho's wettest average snows in a single period.

Basically, the BIPV's can handle 37% of Idaho's wettest and Moscow's average snowfall in a single period.

The roofing tiles are designed to blend seamlessly with a building's shingles or roofing tiles, and can be installed just in just the same way. They can support up to 200 pounds per square foot of snow and they resist wind up to 125 mph. And they come in a variety of colors to match any building's roof.

The Image below is an example of BIPV's in Aspen, Colorado (Ski Resort)





BIPV's typically produce 10-15 watts per square foot  
 On Average, Moscow, Idaho has 4 hours of potential energy producing hours a day

### BIPV Roof square footage of the building

33,760 sq ft  
 3,136 sq m

### According to PVWatt

According to PVWatt in Moscow, Idaho @ 5 degrees, the building can produce:


Typical Performance BIPV: (15%) **484,726 kWh**

High Performance BIPV: (18%) **581,713 kWh**

Premium Performance BIPV: (20%) **646,336 kWh**

### Sun Diagram

@ 12:00 PM






Manufacturer:



Example Diagram:



The calculations here provide the Peak kWh's during the year. This accounts for all the lights on for 12 hours a day in all rooms, including the mechanical room, the electrical room, the offices, and in the storage spaces. To reduce energy consumption, a lighting based control system will control lights, through sensors, to generate the amount of light needed.

Much of the building is well daylite on the south, west, and east side, so the building will save on energy.

|   |  |
|---|--|
| <b>Recommended Levels of lighting</b><br>Circulation areas: 30 Foot-Candles/300 Lux<br>Laboratories: 80 Foot-Candles/800 Lux<br>Study Halls: 30 Foot-Candles/300 Lux  |  |
| <b>1</b>  | <b>2' x 2' 34W LED Panel Light</b><br>Offices, hallways, schools etc.<br>Power: 34W<br>Luminous Flux: 2635 LM<br>Dimensions: 2' x 2' x 3"      |
| <b>2</b>  | <b>2' x 4' 44W LED Panel Light</b><br>Applied in homes, bars, hotels, restaurants, offices, banks etc.<br>Power: 44W<br>Luminous Flux: 4678 LM |
| <b>Foot-Candles</b><br>$E = I/d^2$<br>$I = LM \quad d = \text{distance from plane of luminaire to work plane in ft}$<br>Circulation: $E = 2635/(9.25^2) = 30 \text{ fc}$ - work plane: floor<br>Laboratories: $E = 4678/(7.6^2) = 80 \text{ fc}$ - work plane: 2'6" above floor<br>Study Halls: $E = 2635/(9.25^2) = 30 \text{ fc}$ - work plane: 2'6" above floor  |  |
| <b>Number of Luminaires for Rectangular Spaces</b><br>$\# = (E \times A)/(n \times LM \times CU \times LLF)$<br>LED Light Loss Factor(LLF) = 1 - according to RAB Lighting  |  |
| <b>Cavity Ratio (CR)</b><br>$CR = [5 \times MH(L+W)]/(L \times W)$<br>MH= Room Cavity<br>Example: $CR = [5 \times 9.25(40 + 23)]/(40 \times 23) = 3.16$ so 3<br>From the IES File, the manufacturer provides, take the Cavity Ratio, the Ceiling Cavity reflectance(material) and Wall Surface Reflectance(material) to determine the Coefficient of Utilization (CU)<br>So, from the table, the CU of the example above would be .81 |  |




## Basement




## 1st Floor



## 2nd Floor



## 3rd Floor



### Zones



### Number of Luminaires - Basement

- ① Zone 3: # =  $(30 \text{ fc} \times 920 \text{ sqft}) / (1 \times 2635\text{LM} \times .81 \times 1) = 13 \text{ Luminaires}$
- Zone 5: # =  $(30 \text{ fc} \times 7440 \text{ sqft}) / (1 \times 2635\text{LM} \times 1.05 \times 1) = 80 \text{ Luminaires}$

### Number of Luminaires - 1st Floor

- Zone 1: # =  $(30 \text{ fc} \times 3480 \text{ sqft}) / (1 \times 2635\text{LM} \times .79 \times 1) = 50 \text{ Luminaires}$
- ① Zone 2: # =  $(30 \text{ fc} \times 9012 \text{ sqft}) / (1 \times 2635\text{LM} \times .92 \times 1) = 112 \text{ Luminaires}$
- Zone 3: # =  $(30 \text{ fc} \times 5200 \text{ sqft}) / (1 \times 2635\text{LM} \times .81 \times 1) = 73 \text{ Luminaires}$
- ② Zone 4: # =  $(80 \text{ fc} \times 4400 \text{ sqft}) / (1 \times 4678\text{LM} \times 1.02 \times 1) = 74 \text{ Luminaires}$

### Number of Luminaires - 2nd Floor

- ① Zone 2: # =  $(30 \text{ fc} \times 7756 \text{ sqft}) / (1 \times 2635\text{LM} \times .92 \times 1) = 96 \text{ Luminaires}$
- Zone 3: # =  $(30 \text{ fc} \times 5320 \text{ sqft}) / (1 \times 2635\text{LM} \times .83 \times 1) = 73 \text{ Luminaires}$
- ② Zone 4: # =  $(80 \text{ fc} \times 5240 \text{ sqft}) / (1 \times 4678\text{LM} \times 1.02 \times 1) = 88 \text{ Luminaires}$

### Number of Luminaires - 3rd Floor

- ① Zone 2: # =  $(30 \text{ fc} \times 11175 \text{ sqft}) / (1 \times 2635\text{LM} \times .92 \times 1) = 138 \text{ Luminaires}$
- Zone 3: # =  $(30 \text{ fc} \times 5320 \text{ sqft}) / (1 \times 2635\text{LM} \times .83 \times 1) = 73 \text{ Luminaires}$
- ② Zone 4: # =  $(80 \text{ fc} \times 5240 \text{ sqft}) / (1 \times 4678\text{LM} \times 1.02 \times 1) = 88 \text{ Luminaires}$

### Total Luminaires:

- ① 708 Luminaires
- ② 250 Luminaires

### kWh

- ①  $(708 \text{ Luminaires} \times 34\text{W}) / 1000 = 24.07 \text{ kW}$   
Peak Hours:  $(24.07 \text{ kW} \times 12 \text{ hr})(365 \text{ days}) = 105,435 \text{ kWh/year}$
- ②  $(250 \text{ Luminaires} \times 44\text{W}) / 1000 = 11 \text{ kW}$   
Peak Hours:  $(11 \text{ kW} \times 12 \text{ hr})(365 \text{ days}) = 48,180 \text{ kWh/year}$

**Total:** 153,615 kWh/year



These calculation are based on the amount of equipment NBBJ put into the revit model. The computers were based on the amount of offices and desk spaces.

16 Freezers @ 650W:  $(650W \times 16) = 10,400W$   
 $(10.4 \text{ kW} \times 24 \text{ hr}) \times 365 \text{ days} = 91,105 \text{ kWh/yr}$

12 Frigerators @ 300W:  $(300W \times 12) = 3,600W$   
 $(3.6\text{kW} \times 24 \text{ hr}) \times 365 \text{ days} = 31,536 \text{ kWh/yr}$

6 Incubators @ 400W:  $(400W \times 6) = 2,400W$   
 $(2.4\text{kW} \times 24 \text{ hr}) \times 365 \text{ days} = 21,024 \text{ kWh/yr}$

16 Hoods @ 100W:  $(100W \times 16) = 1,600W$   
 $(1.6\text{kW} \times 12 \text{ hr}) \times 365 \text{ days} = 7,008 \text{ kWh/yr}$

36 Computers w/ power saver @ 85W:  $(85W \times 36) = 3,060W$   
 $(3\text{kW} \times 12 \text{ hr}) \times 365 \text{ days} = 13,402 \text{ kWh/yr}$

2 Coffee Makers @ 800W:  $(800W \times 2) = 1,600W$   
 $(1.6\text{kW} \times 1 \text{ hr}) \times 365 \text{ days} = 584 \text{ kWh/yr}$

4 Copiers/Printers @ 350W:  $(350W \times 4) = 1,400W$   
 $(1.4\text{kW} \times 2 \text{ hr}) \times 365 \text{ days} = 1,022\text{kWh/yr}$


**Appliance Total:** 165,681 kWh/yr




# DETAILED SECTION

TEAM 2

- 1: Earth
- 2: 16" dia. - 40' Concrete Pile
- 3: Steel Footing to Concrete Connector
- 4: 9" x 9" Glue-Laminated Column
- 5: Clear Laminated Double Paned Glazing
- 6: 9" x 3.5" Glue-Laminated Beam
- 7: Western Red Cedar Lap Siding
- 8: 6" deep Insulation
- 9: 230 TGI: 14" Depth - 16" O.C.
- 10: Vapor Barrier
- 11: Western Hemlock Window Molding
- 12: 5/8" Plywood sheathing
- 13: 2" Wood furring
- 14: Steel Glue-Laminated Connector
- 15: 7" x 7" Acrylic Gutter System
- 16: 22.5" x 9" Glue-Laminated Beam
- 17: 1" Ponderosa tongue and groove paneling
- 18: Base Plate for 2" x 6" Framing
- 19: BIPV supports
- 20: 34W LED Luminaire @ 11' 9"
- 21: 7" Concrete Slab
- 22: Tension Cable
- 23: Tension Cable Base
- 24: 15" x 5.5" Glue Laminated Beam
- 25: 2' x 9" Glue-Laminated Beam
- 26: 2" x 8"
- 27: BIPV's
- 28: 10" deep Insulation
- 29: Cedar 3.5" x 3.5" Post(Railing)
- 30: Glass Railing
- 31: Automated Interior Shading







South/West/East Wall:

R-Value: 30.3

U-Value: .03


East/West/South Windows:

Clear Laminated Double Paned  
Glazing

Roof:

R-Value: 57.9

U -Value: .02




North Wall:

R-Value: 37

U-Value: .03

North Windows:

Low Solar-gain Low-E Triple  
Paned Glazing





For heating and cooling, this building will be using a chilled beam system. The University of Idaho provides this opportunity through a heat exchanger.

**Benefits:**

- Uses far less fan energy than a traditional air-based system
  - Temperature required for water in chilled beams is far less extreme than the temperature required for conventional air systems.
  - Chilled beam systems allow for cool air to be distributed more evenly
  - Much more efficient heating and cooling energy transportation costs
  - Maintenance costs are much lower for chilled beam systems
  - Traditional all-air systems use 2 to 2.5 times more space than chilled beam systems
- In addition, chilled beams increase thermal comfort, air quality, and have lower than conventional installation costs.

The calculations provided are the Peak heating and cooling loads to help determine types of equipment.

| Values  |
|---|
| Roof: R-Value: 57.9 U-Value: .02  |
| North Wall: North Wall: R-Value: 37 U-Value: .03  |
| East/West/South Wall: R-Value: 30.3 U-Value: .03  |
| North Windows: U: .24   |
| East/West/South: U: .32   |
| Average Indoor temp. to be maintained for Labs : 65-70 degrees & 70 for offices                                   |
| Heating dry bulb temp. in Spokane, WA is 1 (Closest city to Moscow, ID in table) $\Delta T:(70)-(1)=69$ degrees   |
| Wall Area   |
| Area of North Exterior Wall: 12,719 sqft  |
| Area of North Windows: 1,792 sqft   |
| Area of East/West/South Exterior Walls: 6,864 sqft  |
| Area of East/West/South Windows: 5,915 sqft   |
| Area of Ceiling: 22,527 sqft  |
| Volume of Building: 1,020,240 cubic feet  |
| <b>Calculating Wall/Window transmission Btu/hr: <math>Q = U \times A \times \Delta T</math></b>                   |
| $Q_{ceiling} = (.02 \text{Btu/hr} \times F \times \text{sqft})(22,527 \text{ sqft})(69F) = 31,087 \text{ Btu/hr}$ |
| $Q_{Nwindows} = (.24)(1792)(69) = 29,675 \text{ Btu/hr}$  |
| $Q_{Nwall} = (.03)(12719)(69) = 26,328 \text{ Btu/hr}$  |
| $Q_{E/W/Swindows} = (.32)(5915)(69) = 120,603 \text{ Btu/hr}$   |
| $Q_{E/W/Swall} = (.03)(6864)(69) = 14,208 \text{ Btu/hr}$   |
| <b>Total: 221,901 Btu/hr</b>  |



C = Heat capacity of air

ACH = Air change per hour

C = Usually ranging from .014-.018. Depends on elevation, so .018 for lower elevation

ACH = .41-.59 for energy efficient construction = Avg. = .5

$$Q_{\text{infill}} = C \times \text{ACH} \times V \times \Delta T$$

$$Q_{\text{infill}}: (.018 \text{ Btu/cubicft})(.5)(950,040 \text{ cubicft})(69) = 589,974 \text{ Btu/hr}$$

Heating Load

$$Q_{\text{tr}} = 223,125 \text{ Btu/hr} + 589,974 \text{ Btu/hr} = 813,099 \text{ Btu/hr}$$

### Equipmet Load

$$\text{Appliances: } N \times \text{HG}_{\text{sensible}} \times F_{\text{usage}} \times \text{CLF}$$

$$Q_{\text{Freezer}}: 16(3.41 \times 650\text{W}) \times 1 \times 1 = 35,464 \text{ Btu/hr}$$

$$Q_{\text{Frigerator}}: 12(3.41 \times 300\text{W}) \times 1 \times 1 = 12,276 \text{ Btu/hr}$$

$$Q_{\text{Incubator}}: 6(3.41 \times 400\text{W}) \times 1 \times 1 = 8,184 \text{ Btu/hr}$$

$$Q_{\text{Hoods}}: 16(3.41 \times 100\text{W}) \times 1 \times 1 = 5,456 \text{ Btu/hr}$$

$$Q_{\text{Computer w/ power saver}}: 32(3.41 \times 85\text{W}) \times 1 \times 1 = 9,275 \text{ Btu/hr}$$

$$\text{Total: } 70,655 \text{ Btu/hr}$$

**Occupant Load : 150 People my use the space at one time**

**For heating load,  $Q_{\text{occupant}}: n \times (\text{HG}_{\text{sensible}}) \times \text{CLF}$**

$\text{HG}_{\text{sensible}}$  for occupants generally slow walking = 300 Btu/hr

$$Q_{\text{occupant}} = 150 \times (300 \text{ btu/hr}) \times 1 = 45,000 \text{ Btu/hr}$$



## Window Load

**Q<sub>Solar</sub> transmission: A x SHGS x SHGF x CLF**

**Typical SHGS for commercial buildings is = .70**

**At 12 AM, in December, at 48 degrees latitude the SHGF is the following**

N = 13 Btu/hr x sqft    S = 233 Btu/hr x sqft

E = 14 Btu/hr x sqft    W = 14 Btu/hr x sqft

**CLF for glass with interior shading for north latitude**

N = .06    S = .03

E = .03    W = .04

## Calculations

$Q_{sn} = (1,792 \text{ sqft})(.70)(13 \text{ Btu/hr x sqft})(.06) = 978.4 \text{ Btu/hr}$

$Q_{ss} = (2,375)(.70)(233)(.03) = 11,620 \text{ Btu/hr}$

$Q_{es} = (1854)(.70)(14)(.03) = 545 \text{ Btu/hr}$

$Q_{ws} = (1916)(.70)(14)(.04) = 563 \text{ Btu/hr}$

**Total: 13,707 Btu/hr**

## Lighting Load

**Q<sub>lighting</sub>: = 3.41 x W x F<sub>usage</sub> x CLF**

$QL1 = 3.41(34W \times 708 \text{ Luminaires}) \times .5 \times 1 = 41,042 \text{ Btu/hr}$

$QL2 = 3.41(44W \times 250 \text{ Luminaires}) \times .5 \times 1 = 18,755 \text{ Btu/hr}$

**Total: 59,797 Btu/hr**

## Total Peak Heating Load

**(Q<sub>Wall/Window</sub> Transmission Total + Q<sub>infill</sub>) - Equipment Load - Occupant Load - Q<sub>solar</sub> Transmission - Lighting**

**Total: 813,099 Btu/hr - 70,655 Btu/hr - 45,000 Btu/hr - 13,707 Btu/hr - 59,797 Btu/hr = 623,940 Btu/hr**



## Values

Roof: R-Value: 57.9 U-Value: .02

North Wall: North Wall: R-Value: 37 U-Value: .03

East/West/South Wall: R-Value: 30.3 U-Value: .03

North Windows: U: .24

East/West/South: U: .32

Average Indoor temp. to be maintained for Labs : 65-70 degrees & 70 for offices

The cooling load design conditions in Spokane, WA is 89 (Closest city to Moscow, ID in table)  $\Delta T: (89) - (70) = 19$  degrees

## Wall Area

Area of North Exterior Wall: 12,719 sqft

Area of North Windows: 1,792 sqft

Area of East/West/South Exterior Walls: 6,864 sqft

Area of East/West/South Windows: 5,915 sqft

Area of Ceiling: 22,527 sqft

Volume of Building: 1,020,240 cubic feet

## Calculating Wall/Window transmission Btu/hr: $Q = U \times A \times \Delta T$

$Q_{\text{ceiling}} = (.02 \text{ Btu/hr} \times F \times \text{sqft})(22,527 \text{ sqft})(19\text{F}) = 8,560 \text{ Btu/hr}$

$Q_{\text{Nwindows}} = (.24)(1792)(19) = 8,171 \text{ Btu/hr}$

$Q_{\text{Nwall}} = (.03)(12719)(19) = 7,249 \text{ Btu/hr}$

$Q_{\text{E/W/Swindows}} = (.32)(5915)(19) = 35,963 \text{ Btu/hr}$

$Q_{\text{E/W/Swall}} = (.03)(6864)(19) = 3,912 \text{ Btu/hr}$

**Total: 63,855 Btu/hr**

# COOLING LOAD (CALCULATIONS) 2

C = Heat capacity of air

ACH = Air change per hour

C = 1.1 = the constant 1.1 is based on the heat capacity of air under standard conditions multiplied by 60 minutes.  $.018 \times 60 = 1.1$

ACH = .3 - .38 for energy efficient construction = Avg. = .35

$$Q_{infill} = C \times ACH \times V/60 \times \Delta T$$

$$Q_{infill}: 1.1 \times .35 \times 950,040 \text{ cubicft}/60 \times 19 = 115,825 \text{ Btu/hr}$$

Cooling Load

$$Q_{LT} = 63,855 \text{ Btu/hr} + 115,825 \text{ Btu/hr} = 179,680 \text{ Btu/hr}$$

## Equipmet Load

$$\text{Appliances: } N \times HG_{\text{sensible}} \times F_{\text{usage}} \times CLF$$

$$Q_{\text{Freezer}}: 16(3.41 \times 650W) \times 1 \times 1 = 35,464 \text{ Btu/hr}$$

$$Q_{\text{Frigerator}}: 12(3.41 \times 300W) \times 1 \times 1 = 12,276 \text{ Btu/hr}$$

$$Q_{\text{Incubator}}: 6(3.41 \times 400W) \times 1 \times 1 = 8,184 \text{ Btu/hr}$$

$$Q_{\text{Hoods}}: 16(3.41 \times 100W) \times 1 \times 1 = 5,456 \text{ Btu/hr}$$

$$Q_{\text{Computer w/ power saver}}: 32(3.41 \times 85W) \times 1 \times 1 = 9,275 \text{ Btu/hr}$$

$$\text{Total: } 70,655 \text{ Btu/hr}$$

**Occupant Load : 150 People my use the space at one time**

$$\text{For cooling load, } Q_{\text{occupant}} = n \times (HG_{\text{sensible}} + HG_{\text{latent}}) \times CLF$$

$$HG_{\text{sensible}} \text{ for occupants generally slow walking} = 300 \text{ Btu/hr}$$

$$HG_{\text{latent}} \text{ for occupants generally slow walking} = 330 \text{ Btu/hr}$$

$$Q_{\text{occupant}} = 150 \times (300 \text{ Btu/hr} + 330 \text{ Btu/hr}) \times 1 = 94,500 \text{ Btu/hr}$$

Next page 



## Window Load

$$Q_{\text{Solar transmission}}: A \times \text{SHGS} \times \text{SHGF} \times \text{CLF}$$

Typical SHGS for commercial buildings is = .70

At 12 AM, in August, at 48 degrees latitude the SHGF is the following

$$N = 33 \text{ Btu/hr} \times \text{sqft} \quad S = 189 \text{ Btu/hr} \times \text{sqft}$$

$$E = 36 \text{ Btu/hr} \times \text{sqft} \quad W = 36 \text{ Btu/hr} \times \text{sqft}$$

CLF for glass with interior shading for north latitude

$$N = .06 \quad S = .03$$

$$E = .03 \quad W = .04$$

## Calculations

$$Q_{\text{sn}} = (1,792 \text{ sqft})(.70)(33 \text{ Btu/hr} \times \text{sqft})(.06) = 2,483 \text{ Btu/hr}$$

$$Q_{\text{ss}} = (2,375)(.70)(189)(.03) = 9,426 \text{ Btu/hr}$$

$$Q_{\text{es}} = (1,854)(.70)(36)(.03) = 1,402 \text{ Btu/hr}$$

$$Q_{\text{ws}} = (1,916)(.70)(36)(.04) = 1,931 \text{ Btu/hr}$$

$$\text{Total: } 15,242 \text{ Btu/hr}$$

## Lighting Load

$$Q_{\text{lighting}} = 3.41 \times W \times F_{\text{usage}} \times \text{CLF}$$

$$Q_{\text{L1}} = 3.41(34 \text{ W} \times 708 \text{ Luminaires}) \times .5 \times 1 = 41,042 \text{ Btu/hr}$$

$$Q_{\text{L2}} = 3.41(44 \text{ W} \times 250 \text{ Luminaires}) \times .5 \times 1 = 18,755 \text{ Btu/hr}$$

$$\text{Total: } 59,797 \text{ Btu/hr}$$



## Total Peak Cooling Load

( $Q_{\text{Wall/Window Transmission Total}} + Q_{\text{infill}}$ ) + Equipment Load + Occupant Load +  $Q_{\text{solar Transmission}}$  + Lighting

$$\text{Total: } :179,680 \text{ Btu/hr} - 70,655 \text{ Btu/hr} - 94,500 \text{ Btu/hr} - 15,242 \text{ Btu/hr} - 59,797 \text{ Btu/hr} = 419,884 \text{ Btu/hr}$$

# WATER MANAGEMENT TEAM 2

|   |
|---|
| <b>Rain</b>   |
| Moscow receives 27.3" of rain each year.<br>Drought year(2/3) : 18" of rain a year            |
| <b>Area</b>   |
| The roof is 35,717sq ft (horizontal area)   |
| According to the graph:<br><b>Average: 488,000 gallons</b><br><b>Drought: 310,000 gallons</b> |
| It is recommended that I have a <b>122,000 gallon cistern</b>                                 |
| 1 gallon of water = .1337 cubic feet, so my cistern needs to be at least 16, 311 cubic feet.  |





My site has roughly 51,701 sq ft of plant/grass space

According to LAND ARCH program, the University uses a Fescue Kentucky blue grass blend.  
Fescue/Kentucky blue grass uses .7"-1.2" of water per week

624 gallons (83.3 cubic feet) of water are required to apply 1 inch of water on 1,000 square feet of lawn

I have 1,780 sq ft of covered green spaces

1780 sq ft of green space / 1000 sq ft of 1" water = 1.780  
1.780 x 624 gallons  
1,110.72 gallons = 1" of water on 1,780 sq ft

52 weeks in a year  
-20 weeks of .7" per week = 14 " per year  
-32 weeks of 1.2" per week = 38.4" per year  
-52.4" of rain a year to grow Kentucky bluegrass over a year

52.4" a year x 1,110.72 gallons per 1"  
**Total: 58,201 gallons a year**

Assuming that 150 persons are flushing 3 times a day

Toilets: 1.6 gallons  
Urinals: .5 gallons

450 flushes per day.  
**T: 300 toilets**  
**U: 150 urinals**



**T: 300 x 1.6 gallons = 480 gallons per day**  
**U: 150 x .5 gallons = 75 gallons per day**  
**T + U = 550 gallons per day**

550 x 365 days/yr = **200,750 gallons per year**

**Total Gallons Needed**  
58,201 + 200,750 = **258,951 gallons**

During a drought, I have 58,113 gallons left over  
During the average year I have approximately 236,113 gallons left over

# WATER MANAGEMENT TEAM 2





## Conclusion

Peak Heating Load:

$$(623,940 \text{ Btu/hr})/1000 = 623.94 \text{ kBtu/hr}$$

$$623.94 \text{ kBtu/hr} \times 24 \text{ hr} \times 365 \text{ days} = 5,465,714 \text{ kBtu/yr}$$

$$(5,465,714 \text{ kBtu/yr})/70,503 \text{ sqft} = 78 \text{ kBtu/sf/yr}$$

Peak Cooling Load:

$$(419,884 \text{ Btu/hr})/1000 = 419.88 \text{ kBtu/hr}$$

$$419.88 \text{ kBtu/hr} \times 24 \text{ hr} \times 365 \text{ days} = 3,678,183 \text{ kBtu/yr}$$

$$(3,678,183 \text{ kBtu/yr})/70,503 \text{ sqft} = 52 \text{ kBtu/sf/yr}$$

Peak Electricity Load:

$$165,681 + 153,615 = 319,296$$

$$\text{Total: } (319,296 \text{ kWh/yr})/70,503 = 4.5 \text{ kWh/sf/yr}$$

$$15.35 \text{ kBtu/sf/yr}$$

$$\text{Heating + Cooling Load} = 130 \text{ kBtu/sf/yr}$$

$$\text{Typical BIPV Electricity - Peak Electricity Load} =$$

$$8.12 \text{ kBtu/sf/yr}$$

$$\text{Typical Performance BIPV: } 484,726 \text{ kWh/year} = (484,726 \text{ kWh/yr})/70,503 \text{ sqft} = 6.88 \text{ kWh/sf/yr} \quad - \quad 23.47 \text{ kBtu/sf/yr}$$

$$\text{High Performance BIPV: } 581,713 \text{ kWh/yr} = (581,713 \text{ kWh/yr})/70,503 \text{ sqft} = 8.25 \text{ kWh/sf/yr} \quad - \quad 28.15 \text{ kBtu/sf/yr}$$

$$\text{Premium Performance BIPV: } 646,336 \text{ kWh/yr} = (646,336 \text{ kWh/yr})/70,503 \text{ sqft} = 9.16 \text{ kWh/sf/yr} \quad - \quad 31.25 \text{ kBtu/sf/yr}$$

The carbon foot-print of this building is low. Considering energy savings (Electricity and the use of the local steam plant), local materials, on-site power, and water management

- On an average year, this building can collect 488,000 gallons.

- During a drought year, this building can collect 310,000 gallons.

- 258,951 gallons a year are needed to supply the toilets and the covered vegetation

- Wood/Structure is harvested from sustainable Idaho forest practices

$$\text{Heating + Cooling Load} = 130 \text{ kBtu/sf/yr}$$

$$\text{Typical BIPV Electricity - Peak Electricity Load} = 8.12 \text{ kBtu/sf/yr}$$

- Because of the on-campus steam plant, my total EUI is -8.12 kBtu/sf/yr with typical performing BIPV's

$$\text{EUI: } -8.12 \text{ kBtu/sf/yr}$$