

Anatek Labs, Inc.

1282 Alturas Drive • Moscow, ID 83843 • (208) 883-2839 • Fax (208) 882-9246 • email moscow@anateklabs.com
504 E. Sprague Ste. D • Spokane, WA 99202 • (509)838-3999 • Fax (208) 838-4433 • email spokane@anateklabs.com

CITY OF COLFAX

MATT HAMMER

PO BOX 229

COLFAX, WA 99111

Project: BIOSOLID SAMPLING

Certificate of Analysis

Sample: POND #1 S#2

Sampling Date: 5/3/2005
Sampling Time:
Date Received: 5/3/2005
Lab #: 05X1392-01

Analyte	Result	Units	PQL	Analysis Date	Analyst	Method
Fecal Coliform	>1300000	MPN/g	2	5/6/2005	KAS	SM 9221E
Percent Solids	12.1					

Comments: Results are dry weight basis

Sample: POND #1 S#3

Sampling Date: 5/3/2005
Sampling Time:
Date Received: 5/3/2005
Lab #: 05X1392-02

Analyte	Result	Units	PQL	Analysis Date	Analyst	Method
Fecal Coliform	287000	MPN/g	2	5/6/2005	KAS	SM 9221E
Percent Solids	17.4					

Comments: Results are dry weight basis

Sample: POND #2 S#3

Sampling Date: 5/3/2005
Sampling Time:
Date Received: 5/3/2005
Lab #: 05X1392-03

Analyte	Result	Units	PQL	Analysis Date	Analyst	Method
Fecal Coliform	15500	MPN/g	2	5/6/2005	KAS	SM 9221E
Percent Solids	11					

Comments: Results are dry weight basis

Sample: POND #1 S#4

Sampling Date: 5/3/2005
Sampling Time:
Date Received: 5/3/2005
Lab #: 05X1392-04

Analyte	Result	Units	PQL	Analysis Date	Analyst	Method
Fecal Coliform	112000	MPN/g	2	5/6/2005	KAS	SM 9221E
Percent Solids	21.4					

Comments: Results are dry weight basis

Sample: POND #2 S#1

Sampling Date: 5/3/2005
Sampling Time:
Date Received: 5/3/2005
Lab #: 05X1392-05

Analyte	Result	Units	PQL	Analysis Date	Analyst	Method
Fecal Coliform	1270	MPN/g	2	5/6/2005	KAS	SM 9221E
Percent Solids	15.7					

Comments: Results are dry weight basis

Anatek Labs, Inc.

1282 Alturas Drive • Moscow, ID 83843 • (208) 883-2839 • Fax (208) 882-9246 • email moscow@anateklabs.com
504 E. Sprague Ste. D • Spokane, WA 99202 • (509)838-3999 • Fax (208) 838-4433 • email spokane@anateklabs.com

CITY OF COLFAX

MATT HAMMER
PO BOX 229
COLFAX, WA 99111

Project: BIOSOLID SAMPLING

Certificate of Analysis

Sample: POND #2 S#2

Sampling Date: 5/3/2005
Sampling Time:
Date Received: 5/3/2005
Lab #: 05X1392-06

Analyte	Result	Units	PQL	Analysis Date	Analyst	Method
Fecal Colliform	14800	MPN/g	2	5/6/2005	KAS	SM 9221E
Percent Solids	5.4					

Comments: Results are dry weight basis


Sample: POND #1 S#1

Sampling Date: 5/3/2005
Sampling Time:
Date Received: 5/3/2005
Lab #: 05X1392-07

Analyte	Result	Units	PQL	Analysis Date	Analyst	Method
Fecal Colliform	224000	MPN/g	2	5/6/2005	KAS	SM 9221E
Percent Solids	10.7					

Comments: Results are dry weight basis

Approved by:



Anatek Labs, Inc.

1282 Alturas Drive • Moscow, ID 83843 • (208) 883-2839 • Fax (208) 882-9246 • email moscow@anateklabs.com
504 E Sprague Ste. D • Spokane WA 99202 • (509) 838-3999 • Fax (509) 838-4433 • email spokane@anateklabs.com

CITY OF COLFAX

MATT HAMMER

PO BOX 229

COLFAX, WA 99111

Project: BIOSOLID SAMPLING

Report Date: 19-May-05

Certificate of Analysis

Total Metals - Method EPA 6020/200.8

Sample Name:	COMPOSITE	Analyte	Result	Units	PQL	Method
Sample Location:		Arsenic	5.0	mg/Kg	0.5	EPA 6020A
Sampling Date:	5/3/2005	Cadmium	7.2	mg/Kg	0.5	EPA 6020A
Sampling Time:		Copper	340	mg/Kg	0.5	EPA 6020A
Date Received:	5/3/2005	Lead	197	mg/Kg	0.5	EPA 6020A
Lab #:	05X1392-08	Mercury	9.14	mg/Kg	0.05	EPA 6020A
Matrix:	BIOSOLID	Molybdenum	5.4	mg/Kg	0.5	EPA 6020A
Analysis Date:	5/11/2005	Nickel	20.3	mg/Kg	0.5	EPA 6020A
Analyst:	RAS	Selenium	4.9	mg/Kg	0.5	EPA 6020A
% Solid:	14.4	Zinc	1120	mg/Kg	0.5	EPA 6020A
Wt. Basis:	Dry Wt Basis					

Sample Name:	COMPOSITE	Analyte	Result	Units	PQL	Method
Sample Location:	DUPLICATE	Arsenic	5.0	mg/Kg	0.5	EPA 6020A
Sampling Date:	5/3/2005	Cadmium	6.7	mg/Kg	0.5	EPA 6020A
Sampling Time:		Copper	365	mg/Kg	0.5	EPA 6020A
Date Received:	5/3/2005	Lead	187	mg/Kg	0.5	EPA 6020A
Lab #:	05X1392-08D	Mercury	8.30	mg/Kg	0.05	EPA 6020A
Matrix:	BIOSOLID	Molybdenum	5.2	mg/Kg	0.5	EPA 6020A
Analysis Date:	5/11/2005	Nickel	20.6	mg/Kg	0.5	EPA 6020A
Analyst:	RAS	Selenium	4.7	mg/Kg	0.5	EPA 6020A
% Solid:	14.4	Zinc	1140	mg/Kg	0.5	EPA 6020A
Wt. Basis:	Dry Wt Basis					

Sample Name:	COMPOSITE	Analyte	Result	Units	PQL	Method
Sample Location:	TRIPLICATE	Arsenic	4.6	mg/Kg	0.5	EPA 6020A
Sampling Date:	5/3/2005	Cadmium	6.1	mg/Kg	0.5	EPA 6020A
Sampling Time:		Copper	351	mg/Kg	0.5	EPA 6020A
Date Received:	5/3/2005	Lead	190	mg/Kg	0.5	EPA 6020A
Lab #:	05X1392-08T	Mercury	7.66	mg/Kg	0.05	EPA 6020A
Matrix:	BIOSOLID	Molybdenum	5.3	mg/Kg	0.5	EPA 6020A
Analysis Date:	5/11/2005	Nickel	21.2	mg/Kg	0.5	EPA 6020A
Analyst:	RAS	Selenium	4.6	mg/Kg	0.5	EPA 6020A
% Solid:	14.4	Zinc	1140	mg/Kg	0.5	EPA 6020A
Wt. Basis:	Dry Wt Basis					

Approved by:





1282 Alturas Dr Moscow ID 83843 (208) 883-2839 FAX 882-9246
504 E Sprague Ste D, Spokane WA 99202 (509) 838-3999 FAX 838-4433
Email: moscow@anateklabs.com

May 19, 2005

City of Colfax

PO Box 229
Colfax, WA 99111
Project Manager: Matt Hammer

Laboratory Project # 05X1392-08, 05X1392-08D, 05X1392-08T

Date Sampled: 5/3/05

Project Name: N/A

Date Received: 5/3/05

Results are mg/Kg (ppm) dry weight basis; EDL = Estimated Detection Limit; ND = Not Detected

Sample ID: Composite

Analyte	Method	Result	Duplicate	Triplicate	EDL	Anaysis Date	Analyst
pH	EPA 9045C	6.45	N/A	N/A	N/A	5/13/2005	MBW
Ammonia Nitrogen*	SM4500-NH ₃	2	2	3	1	5/12/2005	MAS
Ammonium Nitrogen*	SM4500-NH ₃	1478	1498	1677	1	5/12/2005	MAS
TKN	SM4500-N _{ORG}	33900	23400	23300	400	5/12/2005	MAS
Total Phosphorous	SM4500-P	7650	9460	6880	500	5/13/2005	MAS
Nitrate/N	EPA 300.0	<4	<4	<4	4	5/12/2005	RAS
Total N	Calc	33900	23400	23300	400	5/12/2005	MAS

Percent Solids 14.4%

* Calculated for 25 C

Approved by: